

ELMICO A/S
Elisabet Norderup Michelson
Sagmoen 100
2223 Galterud
Norway

Reference Test report P 6843-E, date 2010-09-27

SILKO- approval

Finnish Transport Agency's Engineering Structures declares that your products Micopox BP and Micopox BC have been approved to use in SILKO-product file 3.252 chapter 3. as sealing compound. Sealing shall be made as following: 1st layer 500 g/m² + scattering of silica sand size 0,7-1,2 mm 1000 g/m² + 2nd layer 600 g/m².

Product characteristics are following:

- Product identification : Approved
- Viscosity: + ¹⁾
- Pot life: +
- Hardness: +
- Sensitivity to moisture: +
- Water absorption: +
- Detection of pores: +
- Resistance to heat: +
- Frost-salt resistance: +++ ²⁾
- Tensile bond before and after frost-salt resistance test: +++
- Tensile bond on young concrete (7days): +++
- Compalibility with bitumen: +

¹⁾ Scale of critetion: + (approved)

²⁾ Scale of criterion from + to +++ (+ approved, +++ very good/ max)

This approval is valid maximum 5 years from this date.

Development Manager
Engineering Structures

Jouko Lämsä
Jouko Lämsä

NOTICE

- SILKO- working group: concrete
- SILKO- committee
- SILKO- working group: waterproofings and pavements
- J. Huura, Huura Oy

21.3.2011

565/090/2010

- J. Lämsä, Ktay
- E. Pursiainen, Ktay
- R. Bärlund, Ktay
- I. Kuulas, Ktay